

Listing Details FX-15S

Brand Name / Trade Name

/ Model

Product Type

Standard/Program

Company


Contact

FX-15S

Plumbed-In

NSF/ANSI 53 - Drinking Water Treatment Units

Microfilter Co., Ltd.
15-1, Gwinong 3-gil, Deoksan-eup
(162-1 Sansuri, Deoksan-eup)
Jincheon-gun, Chungcheongbuk-do
27856
Republic of Korea
82 43 536 5221



Listing Details by Facility

Replacement Element	Service Cycle (gallons)	Flow Rate (gpm)	Claim(s)	Facility	Related Footnotes
FX-15SR	16,000	2.5	Cyst Reduction Turbidity Reduction	Chungcheongbuk-Do, Korea, Republic of	(1) Claims of capacity or rated service cycle are not applicable for mechanical filtration. [Pb] Product also evaluated and determined to possess weighted average lead content of <=0.25% and complies with lead content requirements for “lead free” plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.
FX-15SR	16000	2.5	Cyst Reduction Turbidity Reduction	# 1 Chungcheongbuk-do, Republic of Korea	[Pb] Product also evaluated and determined to possess weighted average lead content of <=0.25% and complies with lead content requirements for “lead free” plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Disclaimers

The NSF Product Listings show currently listed companies and products. Although every reasonable effort has been made to assure accuracy, omissions or errors may occur due to the complexity of these listings and their conversion for the internet. If you notice an omission or error, please report it to NSF.

Additions shall not be made to this document without prior evaluation and acceptance by NSF.