

Listing Details FX-21

Brand Name / Trade Name

FX-21

/ Model

Product Type

Plumbed-In

Standard/Program

NSF/ANSI 53 - Drinking Water Treatment Units

Company

Microfilter Co., Ltd.
15-1, Gwinong 3-gil, Deoksan-eup
(162-1 Sansuri, Deoksan-eup)
Jincheon-gun, Chungcheongbuk-do
27856
Republic of Korea
82 43 536 5221

Contact



Listing Details by Facility

Replacement Element	Service Cycle (gallons)	Flow Rate (gpm)	Claim(s)	Facility	Related Footnotes
FX-21R	26,000	2.5	Cyst Reduction Turbidity Reduction	Chungcheongbuk-Do, Korea, Republic of	(1) Claims of capacity or rated service cycle are not applicable for mechanical filtration. [Pb] Product also evaluated and determined to possess weighted average lead content of <=0.25% and complies with lead content requirements for “lead free” plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.
FX-21R	26000	2.5	Cyst Reduction Turbidity Reduction	# 1 Chungcheongbuk-do, Republic of Korea	[Pb] Product also evaluated and determined to possess weighted average lead content of <=0.25% and complies with lead content requirements for “lead free” plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Disclaimers

The NSF Product Listings show currently listed companies and products. Although every reasonable effort has been made to assure accuracy, omissions or errors may occur due to the complexity of these listings and their conversion for the internet. If you notice an omission or error, please report it to NSF.

Additions shall not be made to this document without prior evaluation and acceptance by NSF.